



Consumer Confidence Report TCEQ Certificate of Delivery
Texas Commission on Environmental Quality

For Calendar year: 2021 Date Distributed to Customers: June 30, 2022
PWS ID Number: 2150001 PWS Name: City of Breckenridge

You must use at least one direct delivery and at least one good faith delivery method. If your system is under 500 population, please use Small System Certificate of Delivery form.

Direct Delivery Methods

- Mail a paper copy of the CCR
- Mail notification that CCR is available on-line at [http:// https://www.breckenridge.gov/publicworks/page/water-treatment-and-distribution](http://https://www.breckenridge.gov/publicworks/page/water-treatment-and-distribution)
*The Internet link (url) you insert above must take customers directly to the open CCR.
- Email direct web address of the CCR, available at <http://> _____
- Email CCR as an attachment to or an embedded image in an email.
- Other direct delivery (for example, door hangers or additional electronic delivery method).
Please specify: _____

Systems serving 100,000 or more people are required to post the CCR on a publicly available web site and provide the direct URL here: <http://> _____

Good faith delivery methods (To reach people who do not receive bills)

- Posting the CCR on the Internet at <http://>
- Mailing the CCR to people who receive mail, but who do not receive bills.
- Advertising the availability of the CCR in news media.
- Posting the CCR in public places.
- Delivering multiple copies to single billing addresses serving multiple persons.
- Delivering multiple copies of the CCR to community organizations.

I certify that the community water system named above has distributed the Consumer Confidence Report (CCR) for the calendar year of 2021 and that the information in the report is correct and consistent with the compliance monitoring data previously submitted to the TCEQ. Systems serving 100,000 or more people are required to post the CCR on a publicly available web site and provide the direct URL.

Certified By:

Name (print): Houston Satterwhite Title: Assistant City Manager of Operations Phone Number: 254-559-8287
Signature: *H. Satterwhite* Date: 06/30/2022

All systems are required to mail by July 1 the Certificate of Delivery and Consumer Confidence Report to:

Sending by certified mail:

TCEQ
DWSF, MC-155, Attn: CCR,
12100 Park 35 Circle
Austin, TX 78753

Sending by regular mail:

TCEQ
DWSF, MC-155, Attn: CCR, PO Box
13087
Austin, TX 78711-3087

2021 Consumer Confidence Report for Public Water System CITY OF BRECKENRIDGE

This is your water quality report for January 1 to December 31, 2021

For more information regarding this report contact:

CITY OF BRECKENRIDGE provides surface water from **Hubbard Creek Lake, Stephens County**

Name **Houston Satterwhite** ACM of Operations

Phone **254-559-8287**

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (254) 559-8287.

Definitions and Abbreviations

Definitions and Abbreviations

Action Level:

The following tables contain scientific terms and measures, some of which may require explanation.

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Avg:

Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment:

A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment:

A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL:

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG:

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL:

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG:

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

MFL

million fibers per liter (a measure of asbestos)

mrem:

millirems per year (a measure of radiation absorbed by the body)

na:

not applicable.

NTU

nephelometric turbidity units (a measure of turbidity)

pCi/L

picouries per liter (a measure of radioactivity)

Definitions and Abbreviations

- ppb: micrograms per liter or parts per billion
- ppm: milligrams per liter or parts per million
- ppq parts per quadrillion, or picograms per liter (pg/L)
- ppt parts per trillion, or nanograms per liter (ng/L)

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

Information about your Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Information about Source Water

CITY OF BRECKENRIDGE purchases water from WEST CENTRAL TEXAS MWD. WEST CENTRAL TEXAS MWD provides purchase surface water from Hubbard Creek Lake located in Stephens County. [Insert a table containing any contaminant that was detected in the provider's water for this calendar year, unless that contaminant has been separately monitored in your water system (i.e. THM, HAA5, Lead and Copper, Coliforms)].

TCEQ completed an assessment of your source water, and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system is based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system contact Houston Satterwhite, 254-559-8287.

Coliform Bacteria

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform or E. Coli Maximum Contaminant Level	Total No. of Positive E. Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	1 positive monthly sample.	1	0	0	N	Naturally present in the environment.

Lead and Copper	Date Sampled	MCLG	Action Level	90 th Percentile	# Sites over AL	Units	Violation	Likely Source of Contamination
Copper	09/09/2020	1.3	1.3	0	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems
Lead	09/09/2020	0	.015	0	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits

2021 Water Quality Test Results

Disinfection By-Products	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
--------------------------	-----------------	------------------------	-----------------------------	------	-----	-------	-----------	--------------------------------

Haloacetic Acids (HAA5)	2021	23	7.4 - 29.7	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
-------------------------	------	----	------------	-----------------------	----	-----	---	--

*The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year

Total Trihalomethanes (TTHM)	2021	63	34.2 - 76.5	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
------------------------------	------	----	-------------	-----------------------	----	-----	---	--

*The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	2021	0.15	0.15 - 0.15	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Cyanide	2021	101	101 - 101	200	200	ppb	N	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories.
Fluoride	2021	0.2	0.186 - 0.186	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2021	0.0533	0.0533 - 0.0533	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks; sewage; Erosion of natural deposits.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Beta/photon emitters	03/09/2016	8.6	8.6 - 8.6	0	50	pCi/L*	N	Decay of natural and man-made deposits.

*EPA considers 50 pCi/L to be the level of concern for beta particles.

Disinfectant Residual

A blank disinfectant residual table has been added to the CCR template, you will need to add data to the fields. Your data can be taken off the Disinfectant Level Quarterly Operating Reports (DLQR).

Disinfectant Residual	Year	Average Level	Range of Levels Detected	MRDL	MRDLG	Unit of Measure	Violation (Y/N)	Source in Drinking Water
Chloramine	2021	3.4	1.8-4.4	4	4	ppm	N	Water additive used to control microbes.

Turbidity

	Level Detected	Limit (Treatment Technique)	Violation	Likely Source of Contamination
Highest single measurement	0.4 NTU	1 NTU	N	Soil runoff.
Lowest monthly % meeting limit	99%	0.3 NTU	N	Soil runoff.

Information Statement: Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration system and disinfectants.

Total Organic Carbon

The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set, unless a TOC violation is noted in the violations section.